

CITY OF ST. MARYS
2015 WATER QUALITY REPORT
Georgia Water System ID No.: 0390001

Name of Water System Contacts

Wayne Broxton 912-882-4415
911 Dispatcher 912-729-1442

Summary of Water Quality Information

The **City of St. Marys** drinking water system is owned and operated by the **City of St. Marys**. The facility office is located at 418 Osborne Street in St. Marys, Georgia. If there are ever any comments or inquiries to be made, please feel free to contact Wayne Broxton at the number listed above, Monday through Friday, 7:00 AM to 3:30 PM.

Included in this report is information about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The **City of St. Marys** is committed to providing your community with clean, safe, and reliable drinking water. For more information about your water or this report please call Wayne Broxton.

Your water comes from three (3) community *groundwater* wells which have a combined service capacity of approximately 4.1 million gallons per day. The water source for all wells is 800 to 1100 feet deep into what is commonly called the *Upper Floridian Aquifer*. This water source provides ample volumes of water for your community. These wells are distributed throughout the **City of St. Marys**. These properties are protected from activities which could potentially cause contamination of this water source. Treatment is performed at the wells to include removal of contaminants and chlorine disinfection.

A **Wellhead Protection Plan** has been completed for the City. This is a report in which the Georgia Department of Natural Resources Environmental Protection Division identifies any types of pollution to which your water supply could be vulnerable and includes information regarding potential sources of contamination in your watershed. Changes have been made in this system recently; however, the **Wellhead Protection Plan** has not been updated to reflect those changes. The current plan indicates no potential pollution sources present in the fifteen (15) foot control zone for either well.

Cited potential pollution sources in the 100 foot management zone for Well 102 include access and secondary roads, electrical transformers and an above ground storage tank. Cited potential pollution sources in the 100 foot management zone for Well 103 include access and secondary roads, electrical transformers, utility poles, and an above ground storage tank. Cited potential pollution sources in the 100 foot management zone for Well 106 include access and secondary roads as well as a drainage canal. **This report is available upon request at City Hall.**

The **City of St. Marys** conducts laboratory tests for more than eighty (80) drinking water parameters on samples from each of its wells on a periodic basis determined by the Georgia Department of Natural Resources Environmental Protection Division Drinking Water Program and/or the United States Environmental Protection Agency. Generally, samples are collected for analysis of inorganic compounds, volatile organic compounds, radionuclides, and lead and copper once in every three (3) year period whereas nitrates and copper once in a three (3) year cycle whereas nitrates are sampled once a year. The State collects and analyzes samples for synthetic organic compounds once in a three (3) year cycle. Waivers may be issued for the analysis of synthetic organic compounds, cyanide, arsenic and/or asbestos because studies show that the distributed drinking water in this area is not vulnerable to contamination from

these chemicals. If radiological results during the initial radiological monitoring period were below the detection limit, the sampling schedule of once every six (6) to nine (9) years may be utilized for radionuclides. Daily monitoring of chlorine and flow are conducted by City personnel.

During 2015, the parameters for which analyses were conducted included monthly analysis for microbial contaminants, daily analysis for chlorine residuals, annual analysis for nitrates and nitrites, analysis for volatile organic, inorganic and synthetic organic compounds as well as analysis for Total Trihalomethanes and Haloacetic Acids. **All detected contaminants are delineated in the accompanying chart. Any contaminants not listed were not detected or were below reportable limits.**

The City of St. Marys had one (1) violation of water quality parameters during 2015. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Our facility is required to collect twenty (20) drinking water samples to be analyzed for bacterial content every month. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the compliance period of November 1, 2015 through November 30, 2015, results indicated two (2) positive samples for Total Coliform. The standard is that no more than 1 sample per month/5 percent of samples may be positive for Total Coliform.

This resulted in a Maximum Contaminant Level (MCL) violation for the month of November. The samples were immediately transferred to the *E. coli* test and the results were negative. The required six (6) repeat samples and two (2) samples from the ground water sources were collected for Total Coliform and *E. coli* analysis. All repeat and groundwater source samples indicated **NO Total Coliform** bacteria were present. Public Notification was posted for this violation.

What does this mean?

This was not an emergency. If it had been you would have been notified within 24 hours. Total coliform bacteria are generally not harmful themselves.

Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. **We did not find any of these bacteria in our subsequent testing.**

What should I do?

- You did not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

What is being done?

Consumers were notified in December 2015. Notices were sent with water bills and posted in multiple public locations: City Hall, public library, Welcome Center, Public Works, and major apartment complexes. The City of St. Marys Water Department will continue to strive to ensure that the proper treatment and quality of the drinking water meets health standards.

Thirty (30) representative locations have been selected throughout your community where Lead and Copper analyses are conducted. Analysis for the presence of Lead and Copper indicate the presence of service lines containing these materials in some single family residences, multi-family residences, municipal buildings, and/or commercial locations. Results indicated **NO** residences selected contained these components which exceeded the action levels for these parameters.

Lead and Copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes as well as brass fixtures. Lead is found throughout the environment in the air, soil, water and household dust as well as in consumer products such as lead based paint, pottery and pewter. Lead and Copper enter drinking water as a result of the corrosion or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of St. Marys is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

To minimize exposure to Lead and/or Copper, the following measures may be taken.

- When your water has been sitting for several hours, minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.
- Use cold water for drinking or cooking.
- Do not cook with, or consume water, or make baby formula using water from the hot water faucet.
- Use only "lead-free" solder, fluxes and materials in new household plumbing.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. The EPA has established Maximum Contaminant Levels (MCL's) and Maximum Contaminant Level Goals (MCLG's) for potential contaminants. MCL's are the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology. MCLG's are the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety. **More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 800-426-4791.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. **EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that **may** be present in source water include the following:

- **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of Industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The City of St. Marys strives to maintain the highest standards of performance and quality possible. In order to maintain a safe and dependable water supply, improvements that benefit the community must be made. Please help keep these costs as low as possible by utilizing good water conservation practices.

DEFINITION OF TERMS AND ABBREVIATIONS USED IN THIS REPORT

Maximum Contaminant Level (MCL): "The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG as feasible using the best available treatment technology."

Maximum Contaminant Level Goal (MCLG): "The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety."

Action Level (AL): "The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow."

Secondary Maximum Contaminant Level (SMCL): reasonable goals for drinking water quality. Exceeding SMCL's may adversely affect odor or appearance, but there is no known risk to human health.

Treatment Technique (TT): "A required process intended to reduce the level of a contaminant in drinking water."

Maximum Residual Disinfectant Level (MRDL): "The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants."

Not Detected (ND): By regulation, this substance or group of substances was tested for in our finished tap water; however, none was detected at the testing limit.

TTHMs (Total Trihalomethanes): One or more of the organic compounds Chloroform, Bromodichloromethane, Chlorodibromomethane, and/or Bromoform.

n/a: Not applicable to this contaminant.

ppb or ug/l: parts per billion or micrograms per liter.

ppm or mg/l: parts per million or milligrams per liter.

pCi/L: picocuries per liter, a measurement of radiation.

**CITY OF ST. MARYS WATER SYSTEM
2015 WATER QUALITY DATA
WSID: 0390001**

The table below lists all the drinking water contaminants that have been detected in your drinking water. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The data presented in this table is from testing done during the year noted. The Federal Environmental Protection Agency (EPA) and the Georgia Department of Natural Resources Environmental Protection Division (EPD) require monitoring for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

DETECTED INORGANIC CONTAMINANTS TABLE

PARAMETER	UNITS	MCL [SMCL]	MCLG	St. Marys Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Chlorine	ppm	4	**	2.13	1.13 to 2.96	2015	No	Water additive used for the control of microbes
Fluoride	ppm	4 [2]	4	0.56	NA	2015	No	Erosion of natural deposits; promotes strong teeth

DETECTED ORGANIC CONTAMINANTS TABLE

PARAMETER	UNITS	MCL	MCLG	St. Marys Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Haloacetic Acids	ug/l	60	**	20.0	0 to 9.2	2015	No	By product of drinking water disinfection
Total Trihalomethanes	ug/l	80	**	64.7	1.2 to 24	2015	No	By product of drinking water disinfection

OTHER DETECTED UNREGULATED CONTAMINANTS TABLE

PARAMETER	UNITS	MCL [SMCL]	MCLG	St. Marys Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Sodium	ppm	**	**	27	NA	2015	No	Erosion of natural deposits

LEAD AND COPPER MONITORING RESULTS

PARAMETER	UNITS	Action Level	MCLG	St. Marys 90th Percentile	# of sample sites above Action Level	Sample Date	Violation No/Yes	Typical Source of Contaminant
Lead	ppb	15	0	2.5	0	2013	No	Corrosion of household plumbing
Copper	ppm	1.3	1.3	0.055	0	2013	No	Corrosion of household plumbing

MICROBIOLOGICAL MONITORING RESULTS

BIOLOGICAL PARAMETERS	MCL	MCLG	St. Marys Water System Results	Positive Sample Date (Month/year)	Sample Year	Violation No/Yes	Typical Source of Contaminant
Presence or Absence of bacteria in sample	Number of Detections	0	0	11/2015	2015	Yes	Naturally present in the environment
Total Coliform	0	0	0	NA	2015	No	Human and animal fecal waste
Fecal Coliform	0	0	0	NA	2015	No	Human and animal fecal waste

RADIONUCLIDES MONITORING RESULTS

PARAMETER	UNITS	MCL	MCLG	St. Marys Water System Results	Range of Detections	Sample Date	Violation No/Yes	Typical Source of Contaminant
Alpha emitters	pCi/L	15*	0	<1	NA	2013	No	Erosion of natural deposits
Radium 226	pCi/L	5*	0	<1	NA	2013	No	Erosion of natural deposits
Radium 228	pCi/L	5*	0	<1	NA	2013	No	Erosion of natural deposits

* The MCL for alpha emitters is 4 mrem/year. EPA considers 15 pCi/L to be the level of concern for alpha emitters including Radium 226 and/or 5 pCi/L for a combined Radium 226 and Radium 228.

** No established MCL, SMCL or MCLG

M = Monitored through State analysis and facility daily

FTM = Failure to Monitor

NA = Not Applicable

*** Parameters, values and/or sources vary.

R = Resampled, results below action level or not detected