



# MEMORANDUM

## DEPARTMENT OF PUBLIC WORKS

**To: WECC, KBAY, CAMDEN COUNTY HEALTH DEPT, TRIBUNE & GEORGIAN**

**From: WAYNE BROXTON, CITY OF ST. MARYS PUBLIC WORKS**

**Date: Thursday, September 04, 2014**

---

**Subject: SEWER SPILL – Sugarmill Boulevard**

---

Please be advised that the City of St. Marys experienced a sanitary sewer spill on September 3, 2014. The location of the spill was at the corner of Hunt Club Road and Sugarmill Blvd.

Public Works was notified by the 911 Center at approximately 7:30 p.m. The cause of the spill has been determined that Lift Station # 15 experienced an electrical malfunction which caused the sewer to overflow the system and spilled out of the manhole at the corner of Hunt Club Road and Sugarmill Blvd. The sewer went into the storm drainage system which discharges into School House Creek. The amount of the spill is estimated to be less than 1000 gallons.

We have made the proper notifications and our crews are making repairs to the lift station. The EPD Emergency Spill Notification Center was notified number and all spill procedures have been implemented to ensure the safety of our citizens and lesson the environmental impact.

Any questions regarding this occurrence can be directed to Wayne Broxton, Utilities Superintendent at (912) 882-4415.

We apologize for any inconvenience this may cause, and appreciate your cooperation and understanding.